

Client : DATA DISCO  
: 29 ELM CLOSE  
: BROADCLYST  
: EXETER DEVON

Location : 29 ELM  
:  
:  
:

Test Date: 12/09/2010 Test Time: 19:50 User: PETE  
Appliance: 034 RADIO MIC MIXER

Visual Inspection P  
Bond/Cont1 0.061 Ohm P  
Bond/Cont2 0.060 Ohm P  
Bond/Cont3 0.060 Ohm P  
Insulation >50.0 MEG P  
Operation 0.033 kVA P  
Earth Leak 0.940 mA P

Test Date: 12/09/2010 Test Time: 19:54 User: PETE  
Appliance: 035 PC MIXER SYSTEM 2

Visual Inspection P  
Bond/Cont1 0.135 Ohm P  
Bond/Cont2 0.135 Ohm P  
Bond/Cont3 0.139 Ohm P  
Insulation >50.0 MEG P  
Operation 0.019 kVA P  
Earth Leak 0.190 mA P

Test Date: 12/09/2010 Test Time: 20:01 User: PETE  
Appliance: 036 IEC SPLITTER

Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.102 Ohm P  
Bond/Cont2 0.105 Ohm P  
Bond/Cont3 S  
Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 20:00 User: PETE  
Appliance: 037 IEC SPLITTER

Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.107 Ohm P  
Bond/Cont2 0.106 Ohm P  
Bond/Cont3 S  
Insulation >50.0 MEG P

Signature: \_\_\_\_\_

*PL Newman*

Date: \_\_\_\_\_

*14/9/10*

Test Date: 12/09/2010 Test Time: 20:03 User: PETE  
Appliance: 038 (21)0035497059 MAGNUM 850 SMOKE  
Visual Inspection P  
Bond/Cont1 0.024 Ohm P  
Bond/Cont2 0.024 Ohm P  
Bond/Cont3 0.024 Ohm P  
Insulation 7.200 MEG P  
Operation 0.000 kVA P  
Earth Leak 0.000 mA P

Test Date: 12/09/2010 Test Time: 20:04 User: PETE  
Appliance: 039 (21)0035497071 MAGNUM 850 SMOKE  
Visual Inspection P  
Bond/Cont1 0.029 Ohm P  
Bond/Cont2 0.028 Ohm P  
Bond/Cont3 0.029 Ohm P  
Insulation >50.0 MEG P  
Operation 0.000 kVA P  
Earth Leak 0.000 mA P

Test Date: 12/09/2010 Test Time: 20:09 User: PETE  
Appliance: 040 SPECTRA BANK 6  
Visual Inspection P  
Bond/Cont1 0.035 Ohm P  
Bond/Cont2 0.033 Ohm P  
Bond/Cont3 0.031 Ohm P  
Insulation >50.0 MEG P  
Operation 0.011 kVA P  
Earth Leak 0.360 mA P

Test Date: 12/09/2010 Test Time: 20:11 User: PETE  
Appliance: 041 SPECTRA BANK 6  
Visual Inspection P  
Bond/Cont1 0.028 Ohm P  
Bond/Cont2 0.029 Ohm P  
Bond/Cont3 0.031 Ohm P  
Insulation >50.0 MEG P  
Operation 0.011 kVA P  
Earth Leak 0.380 mA P

Test Date: 12/09/2010 Test Time: 18:28 User: PETE  
Appliance: 001 IEC 13A LEAD  
Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.062 Ohm P  
Bond/Cont2 0.063 Ohm P  
Bond/Cont3 S  
Insulation >50.0 MEG P

Signature: \_\_\_\_\_

*PL Newman*

Date: \_\_\_\_\_

*14/9/10*

Test Date: 12/09/2010 Test Time: 18:31 User: PETE  
Appliance: 002 IEC-13A LEAD  
Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.071 Ohm P  
Bond/Cont2 0.071 Ohm P  
Bond/Cont3 S  
Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 18:33 User: PETE  
Appliance: 003 IEC-IEC LEAD  
Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.137 Ohm P  
Bond/Cont2 S  
Bond/Cont3 S  
Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 18:35 User: PETE  
Appliance: 004 IEC-13A LEAD  
Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.077 Ohm P  
Bond/Cont2 0.077 Ohm P  
Bond/Cont3 S  
Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 18:37 User: PETE  
Appliance: 005 13A-4WAY EXT  
Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.090 Ohm P  
Bond/Cont2 0.086 Ohm P  
Bond/Cont3 0.085 Ohm P  
Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 18:39 User: PETE  
Appliance: 006 13A-6WAY EXT  
Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.199 Ohm P  
Bond/Cont2 0.203 Ohm P  
Bond/Cont3 0.213 Ohm P  
Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 18:43 User: PETE  
Appliance: 007 13A-NEUTRIK  
Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.235 Ohm P  
Bond/Cont2 S  
Bond/Cont3 S  
Insulation >50.0 MEG P

Signature: \_\_\_\_\_

*PL Newman*

Date: \_\_\_\_\_

*14/9/10*

Test Date: 12/09/2010 Test Time: 18:44 User: PETE  
 Appliance: 008 13A-NEUTRIK  
 Visual Inspection P  
 Extension Lead P  
 Bond/Cont1 0.234 Ohm P  
 Bond/Cont2 S  
 Bond/Cont3 S  
 Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 18:45 User: PETE  
 Appliance: 009 13A-NEUTRIK  
 Visual Inspection P  
 Extension Lead P  
 Bond/Cont1 0.235 Ohm P  
 Bond/Cont2 S  
 Bond/Cont3 S  
 Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 18:47 User: PETE  
 Appliance: 010 LIGHT CONTROL SYSTEM  
 Visual Inspection P  
 Bond/Cont1 0.164 Ohm P  
 Bond/Cont2 0.161 Ohm P  
 Bond/Cont3 0.162 Ohm P  
 Insulation >50.0 MEG P  
 Operation 0.009 kVA P  
 Earth Leak 0.000 mA P

Test Date: 14/09/2010 Test Time: 19:00 User: PETE  
 Appliance: 011 13A-16A ARCTIC LEAD  
 Visual Inspection P  
 Extension Lead P  
 Bond/Cont1 0.857 Ohm F  
 Bond/Cont2 S  
 Bond/Cont3 S  
 Insulation S

Test Date: 14/09/2010 Test Time: 18:55 User: PETE  
 Appliance: 012 13A-16A ARCTIC LEAD  
 Visual Inspection P  
 Extension Lead P  
 Bond/Cont1 0.868 Ohm F  
 Bond/Cont2 S  
 Bond/Cont3 S  
 Insulation S

Test Date: 12/09/2010 Test Time: 19:12 User: PETE  
 Appliance: 023 15000061 EVL MINI SPOT  
 Visual Inspection P  
 Bond/Cont1 0.065 Ohm P  
 Bond/Cont2 0.064 Ohm P  
 Bond/Cont3 0.067 Ohm P  
 Insulation >50.0 MEG P  
 Operation 0.221 kVA P  
 Earth Leak 0.000 mA P  
 Signature: PL Newman Date: 14/9/10

Test Date: 12/09/2010 Test Time: 19:15 User: PETE  
Appliance: 024 13A-IEC  
Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.049 Ohm P  
Bond/Cont2 S  
Bond/Cont3 S  
Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 19:16 User: PETE  
Appliance: 025 15000067 EVL MINI SPOT  
Visual Inspection P  
Bond/Cont1 0.066 Ohm P  
Bond/Cont2 0.066 Ohm P  
Bond/Cont3 0.066 Ohm P  
Insulation >50.0 MEG P  
Operation 0.251 kVA P  
Earth Leak 0.000 mA P

Test Date: 12/09/2010 Test Time: 19:20 User: PETE  
Appliance: 026 115011 MC2 T1500 AMP  
Visual Inspection P  
Bond/Cont1 0.152 Ohm P  
Bond/Cont2 0.150 Ohm P  
Bond/Cont3 0.113 Ohm P  
Insulation >50.0 MEG P  
Operation 0.059 kVA P  
Earth Leak 0.000 mA P

Test Date: 12/09/2010 Test Time: 19:33 User: PETE  
Appliance: 029 13A-IEC  
Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.058 Ohm P  
Bond/Cont2 S  
Bond/Cont3 S  
Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 19:09 User: PETE  
Appliance: 030 IEC-IEC  
Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.127 Ohm P  
Bond/Cont2 S  
Bond/Cont3 S  
Insulation >50.0 MEG P

Signature: PL NewmanDate: 14/9/10

Test Date: 12/09/2010 Test Time: 19:39 User: PETE  
Appliance: 032 EVL MICRO OCONTROLLE  
Visual Inspection P  
Bond/Cont1 0.136 Ohm P  
Bond/Cont2 0.136 Ohm P  
Bond/Cont3 0.136 Ohm P  
Insulation >50.0 MEG P  
Operation 0.000 kVA P  
Earth Leak 0.000 mA P

Test Date: 12/09/2010 Test Time: 19:35 User: PETE  
Appliance: 031 PC MIXER SYSTEM 1  
Visual Inspection P  
Bond/Cont1 0.167 Ohm P  
Bond/Cont2 0.164 Ohm P  
Bond/Cont3 0.163 Ohm P  
Insulation >50.0 MEG P  
Operation 0.019 kVA P  
Earth Leak 0.000 mA P

Test Date: 12/09/2010 Test Time: 18:52 User: PETE  
Appliance: 013 IEC-IEC  
Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.128 Ohm P  
Bond/Cont2 S  
Bond/Cont3 S  
Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 18:53 User: PETE  
Appliance: 014 IEC-IEC  
Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.128 Ohm P  
Bond/Cont2 S  
Bond/Cont3 S  
Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 18:55 User: PETE  
Appliance: 015 IEC-IEC  
Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.129 Ohm P  
Bond/Cont2 S  
Bond/Cont3 S  
Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 18:57 User: PETE  
Appliance: 016 13A-IEC  
Visual Inspection P  
Extension Lead P  
Bond/Cont1 0.067 Ohm P  
Bond/Cont2 S  
Bond/Cont3 S  
Insulation >50.0 MEG P  
Signature: PL Newman Date: 14/9/10

Test Date: 12/09/2010 Test Time: 18:58 User: PETE  
 Appliance: 017 13A-4WAY EXT  
 Visual Inspection P  
 Extension Lead P  
 Bond/Cont1 0.082 Ohm P  
 Bond/Cont2 0.082 Ohm P  
 Bond/Cont3 0.080 Ohm P  
 Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 18:59 User: PETE  
 Appliance: 018 13A-13A 2 WAY EXT  
 Visual Inspection P  
 Extension Lead P  
 Bond/Cont1 0.251 Ohm P  
 Bond/Cont2 0.248 Ohm P  
 Bond/Cont3 S  
 Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 19:02 User: PETE  
 Appliance: 019 STROBE  
 Visual Inspection P  
 Bond/Cont1 0.125 Ohm P  
 Bond/Cont2 0.120 Ohm P  
 Bond/Cont3 0.119 Ohm P  
 Insulation >50.0 MEG P  
 Operation 0.000 kVA P  
 Earth Leak 0.000 mA P

Test Date: 12/09/2010 Test Time: 19:04 User: PETE  
 Appliance: 020 STROBE  
 Visual Inspection P  
 Bond/Cont1 0.126 Ohm P  
 Bond/Cont2 0.146 Ohm P  
 Bond/Cont3 0.153 Ohm P  
 Insulation >50.0 MEG P  
 Operation 0.000 kVA P  
 Earth Leak 0.000 mA P

Test Date: 12/09/2010 Test Time: 19:06 User: PETE  
 Appliance: 021 IEC-IEC  
 Visual Inspection P  
 Extension Lead P  
 Bond/Cont1 0.127 Ohm P  
 Bond/Cont2 S  
 Bond/Cont3 S  
 Insulation >50.0 MEG P

Test Date: 12/09/2010 Test Time: 19:08 User: PETE  
 Appliance: 022 IEC-IEC  
 Visual Inspection P  
 Extension Lead P  
 Bond/Cont1 0.137 Ohm P  
 Bond/Cont2 S  
 Bond/Cont3 S  
 Insulation >50.0 MEG P  
 Signature: PL Newman Date: 14/9/10

Test Date: 12/09/2010 Test Time: 19:28 User: PETE  
 Appliance: 027 21022 T1000 PANARAY CONT  
 Visual Inspection P  
 Bond/Cont1 0.055 Ohm P  
 Bond/Cont2 0.054 Ohm P  
 Bond/Cont3 0.054 Ohm P  
 Insulation >50.0 MEG P  
 Operation 0.013 kVA P  
 Earth Leak 0.220 mA P

Test Date: 12/09/2010 Test Time: 19:25 User: PETE  
 Appliance: 028 31347 T1000 PANARAY CONT  
 Visual Inspection P  
 Bond/Cont1 0.116 Ohm P  
 Bond/Cont2 0.119 Ohm P  
 Bond/Cont3 0.124 Ohm P  
 Insulation >50.0 MEG P  
 Operation 0.053 kVA P  
 Earth Leak 0.290 mA P

Signature: PL Newman

Date: 14/9/10